## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

**LISTING No**: 7165-0026:298 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001

Contact: Paul Mattern (978) 731-8542 \*Fax (978) 731-8881

**DESIGN**: Model C-6000 fire alarm control unit. Power-limited, automatic, manual, coded, non coded,

local, auxiliary, remote station, central station, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational

considerations. System components:

C-6000 Control Unit

4180 Status Display Module 5220 Direct Connect Module 5395 Distributed Power Module

7181 Zone Converter 7628, 7641 EOL Resistor 5197 Power Supply

**INSTALLATION**: In accordance with listee's printed installation instructions, applicable codes & ordinances and

in a manner acceptable to the authority having jurisdiction.

**MARKING**: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed electrically and functionally

compatible initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per

NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

**NOTE:** For *Fire Alarm Verification Feature*, the maximum Retard/Reset/Restart period must be

adjusted to 30 seconds or less.

**NOTE**: Formerly 7165-1493:173

**XLF:** 7165-0559:125

\*Rev. 05-13-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: MAY 13, 2003 Listing Expires June 30, 2004

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager